



oer 300∖

NMWU 300V CSA

| 3C 2C | Part No. | Power Conductor | | Bonding Conductor | Insulation Thickness | | Jacket Thickness | | Cable O.D. | | Cable Weight | | Ampacity |
|-------|--------------|--------------------|-----|----------------------|-------------------------|------|---------------------|------|---------------|-------------|-----------------|------|----------|
| | | Conductor Count | AWG | AWG | in | mm | in | mm | in | mm | lbs | kg | А |
| | 3810802 | 2 | 8/7 | 10/1 | 0.075 | 1.90 | 0.045 | 1.14 | 0.816 | 20.7 | 277 | 412 | 55 |
| | 3810802BFLAT | 2 | 8/7 | 10/1 | 0.075 | 1.90 | 0.045 | 1.14 | 0.816 x 0.408 | 20.7 x 10.3 | 263 | 392 | 55 |
| | 3810602 | 2 | 6/7 | 10/1 | 0.090 | 2.28 | 0.045 | 1.14 | 0.790 | 20.1 | 382 | 568 | 75 |
| | 3810803 | 3 | 8/7 | 10/1 | 0.075 | 1.91 | 0.045 | 1.14 | 0.702 | 17.8 | 338 | 503 | 55 |
| | 3810603 | 3 | 6/7 | 10/1 | 0.090 | 2.28 | 0.045 | 1.14 | 0.844 | 21.4 | 489 | 728 | 75 |
| | 3810403 | 3 | 4/7 | 8/7 | 0.090 | 2.28 | 0.060 | 1.52 | 0.997 | 25.3 | 759 | 1129 | 95 |
| | 3810203 | 3 | 2/7 | 8/7 | 0.090 | 2.28 | 0.060 | 1.52 | 1.126 | 28.6 | 1220 | 1815 | 130 |

Ampacity values based on CE Code Part I 2021, Table 2. Correction factors may apply. Dimensions and weights are nominal and subject to change without notice.

Specifications and Compliances

- CSA C22.2 No. 48, Nonmetallic sheathed cable
- CSA C22.2 No. 75, Thermoplastic Insulated Wire and Cables
- CSA C22.2 No. 2556, FT1 Vertical Propagation Flame Test
- Conductor Stranded Bare Soft Copper, ASTM B8
- Insulation Polyvinyl Chloride (PVC) Insulation CSA Type TWU 60°C dry/wet 300V

| Bonding | Stranded Bare Soft Copper, ASTM B8 | | | | | |
|-------------|------------------------------------|--|--|--|--|--|
| Jacket | Polyvinyl Chloride (PVC) | | | | | |
| Colour Code | Black, White and Red | | | | | |

Applications

- For exposed and concealed wiring in dry or damp locations and in Category 1 and 2 locations, where not exposed to mechanical damage.
- For exposed wiring in wet locations and where subjected to the weather.
- For direct earth burial (with protection as required by inspection authority) and in accordance with CE Code part I Rule 6-300.





